REPORT ALL

OIL AND HAZARDOUS SUBSTANCE SPILLS

ALASKA LAW REQUIRES REPORTING OF ALL SPILLS

During normal business hours

contact the nearest DEC Area Response Team office:

Central Area Response Team: Anchorage

Northern Area Response Team: Fairbanks

Southeast Area Response Team: Juneau 269-3063

fax: 269-7648

451-2121

fax: 451-2362

465-5340

fax: 465-2237

Outside normal business hours, call: 1-800-478-9300

Division of Spill Prevention and Response



Alaska Department of Environmental Conservation

PORT EDAS DON CITY

rev. 4/2002

Northern

Alaska

Southeas

Alaska

Central

Alaska Department of Environmental Conservation

Discharge Notification and Reporting Requirements

AS 46.03.755 and 18 AAC 75 Article 3

Notification of a discharge must be made to the nearest Area Response Team during working hours:

Anchorage: 269-3063 Fairbanks: 451-2121 Juneau: 465-5340

269-7648 (FAX) 451-2362 (FAX) 465-2237 (FAX)

OR

to the 24-Hour Emergency Reporting Number during non-working hours: 1-800-478-9300

Notification Requirements

Hazardous Substance Discharges

Any release of a hazardous substance must be reported as soon as the person has knowledge of the discharge.

Oil Discharges

■ TO WATER

Any release of oil to water must be reported as soon as the person has knowledge of the discharge.

■ TO LAND

- Any release of oil in excess of 55 gallons must be reported as soon as the person has knowledge of the discharge.
- Any release of oil in **excess of 10 gallons but less than 55 gallons** must be reported within 48 hours after the person has knowledge of the discharge.
- A person in charge of a facility or operation shall maintain, and provide to the Department on a monthly basis, a written record of any discharge of oil *from 1 to 10 gallons*.

■ TO IMPERMEABLE SECONDARY CONTAINMENT AREAS

• Any release of oil *in excess of 55 gallons* must be reported within 48 hours after the person has knowledge of the discharge.

Special Requirements for Regulated Underground Storage Tank (UST) Facilities*

If your **release detection system** indicates a possible discharge, or if you notice **unusual operating conditions** that might indicate a release, you must notify the Storage Tank Program at the nearest DEC Office **within 7 days**:

Anchorage: (907) 269-7504 Fairbanks: (907) 451-2360 Juneau: (907) 465-5200 Soldotna: (907) 262-5210

*Regulated UST facilities are defined at 18 AAC 78.005 and do not include heating oil tanks.